



**Tender text: Ampatop Seal
Weldable roof membrane**

Position	Specifications
----------	----------------

1 General
Carrying out Ampatop Seal in connection with Ampacoll system sealing technology as roof membrane according to country-specific standards

Technical Specifications:

Roll dimensions: 1.5 m x 30 m / 3.0 m x 20 m / 1.5 m x 400 m / 3.0 m x 400 m
 sD value: 0.20 m
 Weight: 350 g/m²
 Fire index: 4.2, VKF
 Fire performance: E, EN 13501-1
 CE marking: EN13859-1:2014

2 Delivery and laying of the weldable roof membrane Ampatop Seal on pressure-proof, clean, and level surfaces parallel to the eaves or the rafters. In case of roof pitch between 5° and 10° use boarding or wood boards to prevent water pockets.

Build all joints with 10 cm overlaps, fasten concealed with clamps or clout nails in the overlap area.

Seal all overlaps either with Ampacoll LiquiSeal or with hot air. Carry out diagonal joints the same way.

Bottom membrane laid on intake sheet, top membrane pulled over roofridge.

Seal nail and screw locations of the counter battens with Ampacoll ND or Ampacoll ND tape. Use Ampacoll ND Duo for roof pitch below 25° DN.

Roof pitch:.....
(minimum pitch 5°)

Roof shape:.....

Quantity.....m² Unit price..... Total price.....

3 Sealing work (surcharges to item 2)

3.1 Installation of boards
Boards on breakthroughs such as chimneys, skylights, and other installations have to be carried out with membrane strips, at least 15 cm high, and sealed with Ampacoll LiquiSeal or hot air.

Quantity.....running metre Unit price..... Total price.....

Note

Content considerations

Adjustments by the user will remain necessary on occasion. Texts for tender proposals describe standard situations only. Special cases must be considered separately. When carrying out the creation, Ampack AG is guided by the best available technology, the recognised rules of the building trade, association requirements and current standards and regulations. In the event of doubt, the details in the documentation or in the brochures and flyers of Ampack AG apply.

Legal considerations

The preparation of texts for invitations to tender is a voluntary, non-payable additional service of Ampack, and is intended as an aid for architects, planners and processors. It is carried out to the best of the company's knowledge, but expressly excludes any liability derived from consulting services. See the General Terms & Conditions of Ampack AG for further information.

Permission for use by customers of Ampack AG

The texts for invitations to tender can be used by our customers (architects, planners and processor) for their own purposes. Any disclosure or publication in printed matter or electronic media is not permitted. Constructive criticism and amendments are expressly requested and welcomed by the author. To facilitate the transfer to tender proposals, unnecessary formatting has been omitted.

Ampack AG
Ulrich Höing
Head Technology and Development
Seebileichstrasse 50
CH-9400 Rorschach
+41 71 858 38 00 Tel
+41 71 858 38 37 Fax
ulrich@ampack.ch

Copyright Ampack AG, CH-9400 Rorschach

Last updated: 28.09.2018